


I have reviewed the attached "Report of Annual Inspection of CCR Surface Impoundment" for the Plant Crist gypsum storage facility and hereby certify that it meets the requirements of 40 C.F.R. 257.83(b)(2).


James C. Pegues, P.E.

1/19/16
Date

257.83 (b)(2)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT		
	FACILITY NAME: Plant Crist - Gypsum Area 1, Cell 2		
	OWNER/OPERATOR OF FACILITY: Gulf Power		
	INSPECTION DATE: December 11, 2015		
	INSPECTING ENGINEER: Hugh H. Armitage, PE (GA 21693)		
	Based on the results of my inspection and review of the data provided, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b).		
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?	N/A*	
	(IF YES, DESCRIBE):		
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION	NO INSTRUMENTATION	
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION	N/A*	
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION		
	MIN. DEPTH: N/A	MAX. DEPTH: N/A	PRESENT DEPTH: 1.55 ft. (avg.)**
	MIN. ELEVATION: N/A	MAX. ELEVATION: N/A	PRESENT ELEVATION: 111.5 ft. **
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.		
	MIN. DEPTH: N/A	MAX. DEPTH: N/A	PRESENT DEPTH: 9.0 ft. (avg.)**
	MIN. ELEVATION: N/A	MAX. ELEVATION: N/A	PRESENT ELEVATION: 111.5 ft. (avg.)**
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.	347,305 yd ³ ** (Phase 1)	
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION	WATER: 24,635 yd ³ (avg.) **	CCR: 205,143 yd ³ (avg.)**
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?	NO	
	(IF YES, DESCRIBE):		
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?	N/A*	
	(IF YES, DESCRIBE):		

* This is the first 'Annual inspection by a qualified professional engineer' performed in accordance with 40 CFR Part 257.83. This information will be included in subsequent annual inspection reports.

** Depths, elevations and cubic yard volumes are estimates derived by qualified personnel from available information.

