257.83	REPORT OF ANNUAL INSPECTION OF CCR S	SURFAC	E IMPO	UNDMENT	
(b)(2)					
	FACILITY NAME: Plant Crist - Gypsum Storage Area				
	OWNER/OPERATOR OF FACILITY: Gulf Power				
	INSPECTION DATE: November 28, 2017				
	INSPECTING ENGINEER: Jacob A. Jordan, P.E. (FL PE# 80903)				
	Based on the results of my inspection and review of the data provided, it is my professional				
/:\	opinion that the report has been completed in accordance with 40 CFR 257.83(b).				
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?		NO		
	(IF YES, DESCRIBE):				
	(II TES, DESCRIBE).				
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION		NO INSTRUMENTATION		
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT		N/A		
	SINCE PREVIOUS ANNUAL INSPECTION				
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE				
	IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION*				
	MIN. DEPTH: 0 ft MAX. DEPTH: 9 ft	PRESEN	IT DEPTH: 9 ft		
	MIN. ELEVATION: 36.31 MAX. ELEVATION: 40.31 PRESENT ELEVATION				
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.*				
	MIN. DEPTH: 0 ft MAX. DEPTH: 11.0 ft	PRESEN	NT DEPTH: 11.0 ft		
	MIN. ELEVATION: 28.3 ft MAX. ELEVATION: 39.3 ft	PRESEN	RESENT ELEVATION: 39.3 ft.		
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING				
	STRUCTURE AT TIME OF INSPECTION.*		347,305 yd ³		
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER AND	WATE	R:	CCR:	
	CCR AT TIME OF INSPECTION*	75,00	0 yd³	204,400 yd ³	
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL				
	STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO				
	ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE		NO		
	THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?				
	(IF YES, DESCRIBE):				
	(IF FES, DESCRIBE).				
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED T	HE			
	STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?			NO	
	(IF YES, DESCRIBE):				
		-			
		3.			

^{*} Depths, elevations and cubic yard volumes are estimates derived by qualified personnel from available information.

Based on the results of my inspection and review of the data provided, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b).

Jacob A. Jordan, P.E.

1/16/18

Date