257.83 (b)(2)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT					
	FACILITY NAME: Plant Smith – Ash Pond					
	OWNER/OPERATOR OF FACILITY: Gulf Power					
	INSPECTION DATE: November 9, 2016					
	INSPECTING ENGINEER: Jacob A. Jordan, P.E. (FL PE# 80903)					
S	Based on the results of my inspection and review of the data provided, it is my professional					
	opinion that the report has been completed in accordance with 40 CFR 257.83(b).					
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING				NO	
<u> </u>	STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?					
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION			NO INSTRUMENTATION		
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT			N/A		
	SINCE PREVIOUS ANNUAL INSPECTION					
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF T					
-	IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION*					
	MIN. DEPTH: 0 ft	MAX. DEPTH: 9.2 ft		r dept	H: 9.2 ft. (at deepest	
	MUNI ELEVATION 42.2	NANY FLEWATION AT OF	area)			
/···\	MIN. ELEVATION: 13.3	MAX. ELEVATION: 17.05	PRESENT. ELEVATION: 13.3			
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR					
	SINCE PREVIOUS ANNUAL INSPECTION.**  MIN. DEPTH: 3 ft MAX. DEPTH: 12 ft		PRESENT DEPTH: 12 ft (at deepest			
	WIIN. DEPTH. 5 IL	I WAA. DEPTH: 12 IL	area)	DEPI	n: 12 it (at deepest	
	MIN. ELEVATION: 4.1 ft	MAX. ELEVATION: 24.4 ft		r ci cv	ATION: up to 24.4 ft	
(iv)	APPROXIMATE STORAGE		PRESENT ELEVATION: up to 24.4 ft			
(10)	IMPOUNDING STRUCTURE AT TIME OF INSPECTION		3,771,000 yd <sup>3</sup> **			
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER		WATED.	WATER:		
(*)	AND CCR AT TIME OF INSPECTION		209,000 yd <sup>3</sup>		CCR: 3,467,744 yd <sup>3</sup>	
(vi)	ANY APPEARANCE OF AN		203,000 yu			
(4.,	STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO					
	ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE			NO NO		
	THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF					
	THE CCR UNIT AND APPURTENANT STRUCTURES?				8	
	(IF YES, DESCRIBE):					
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE					
	STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL			NO		
	INSPECTION?				or U	
	(IF YES, DESCRIBE):					

<sup>\*</sup>Water elevation measured at stoplogs

<sup>\*\*</sup>Depths, elevations and cubic yard volumes are estimates derived by qualified personnel from available information.

Based on the results of my inspection and review of the data provided, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b).

Jaeob A. Jordan, P.E.

1/12/17

Date